



NOTES:

1. It is necessary to ensure the minimum dimensions shown are suitable for the existing ground conditions.
2. A minimum concrete strength of 3000 PSI is recommended. The concrete should be vibrated to eliminate air pockets.
3. Expansion and crack control joints are recommended to protect the channel and the concrete surround.
4. The finished level of the concrete surround must be approx. 1/8" (3) above the top of the channel edge.
5. Refer to Jay R. Smith's latest installation instructions for complete details.

Engineering advice may be required.

SMITH DRAINAGE SYSTEMS



SMITH® JAY R. SMITH MFG. CO.®
MEMBER OF MORRIS GROUP INTERNATIONAL™
www.jrsmith.com
CUSTOMER DRIVEN SINCE 1926

INSTALLATION DRAWING

**9930 SERIES TRENCH DRAIN - LOAD CLASS A-C
INSTALLED IN CONCRETE**



WARNING: Cancer and Reproductive Harm - www.P65Warnings.ca.gov

PM 1464