



NOTES:

1. Concrete encasement dimensions are minimum requirements. Thickness of concrete around trench should match slab thickness.
2. A minimum concrete strength of 4000 PSI is recommended. The concrete should be vibrated to eliminate air pockets.
3. Expansion and crack control joints are recommended to protect the channel and the concrete surround.
4. The finished level of the concrete surround must be approx. 1/8" (3) above the top of the channel edge.
5. Refer to Jay R. Smith's latest installation instructions for complete details.

Engineering advice may be required.

SMITH DRAINAGE SYSTEMS

SMITH® JAY R. SMITH MFG. CO.®
 MEMBER OF MORRIS GROUP INTERNATIONAL
 www.jrsmith.com
 CUSTOMER DRIVEN SINCE 1926

INSTALLATION DRAWING

9931 SERIES TRENCH DRAIN-LOAD CLASS E INSTALLED IN ASPHALT

WARNING: Cancer and Reproductive Harm - www.P65Warnings.ca.gov

PM 1465-A