

H

**SMITH® JAY R. SMITH MFG. CO.®**  
 MEMBER OF MORRIS GROUP INTERNATIONAL  
 POST OFFICE BOX 3237  
 MONTGOMERY, ALABAMA 36109-0237 (USA)  
 TEL: 334-277-8520 FAX: 888-377-7818 www.jrsmith.com



LOCATION

# NON-FREEZE ROOF HYDRANT

DRAWING NUMBER  
**S5907**

SIZE  
**A**

SCALE:  
**NONE**

DATE:  
**6-28-11**




APPROVED BY:  
**CL**

CHECKED BY:  
**CL**

DRAWN BY:  
**TBW**

**5907**

WE CAN ASSUME NO RESPONSIBILITY FOR USE OF SUPERSEDED OR VOID DATA



- NOTE: 1.** Drain Hole must be piped and discharged to an acceptable discharge point. Failure to do so will result in potential water damage which Smith is not responsible.
- 2.** Hose must be removed to allow proper draining of the casing. Smith is not responsible for any casings that burst or related incidents if the hose is not removed.
- 3.** The AB100, AB1953, California Lead Law, and NSF/ANSI Standard 61- Drinking Water System Components are not applicable to Jay R. Smith hydrants as they do not convey/dispense water for human consumption through drinking or cooking.
- 4.** Dimensions shown in parentheses are in millimeters.
- 5. FOR IRRIGATION PURPOSES ONLY.**

**REGULARLY FURNISHED:**  
 Non-Freeze Roof Hydrant with Check Valve, Galvanized Casing and Adjustable Flow Wheel Lock Handle with Deck Flange and Under Deck Clamp.

REV.	DATE	DESCRIPTION	BY	CKD. BY	WEIGHT POUNDS	VOLUME CUBIC FEET	FIGURE NUMBER <b>5907</b>
	8-4-23	Removed Function	HS	CL			
	3-22-23	Revised Notes/Removed ALS/TL	KK	JT			
	1-18-23	Updated Truesdail Note	KK	CL			
	1-9-15	Revised Callout	TBW	CL			