



**NOTES:**

1. Concrete encasement dimensions *are minimum requirements*. *Thickness of concrete around trench should match slab thickness.*
2. A minimum concrete strength of 3000 PSI is recommended. The concrete should be vibrated to eliminate air pockets.
3. Expansion and crack control joints are recommended to protect the channel and the concrete surround.
4. The finished level of the concrete surround must be approx. 1/8" (3) above the top of the channel edge.
5. Refer to Jay R. Smith's latest installation instructions for complete details.

*Engineering advice may be required.*

**SMITH DRAINAGE SYSTEMS**

**SMITH® JAY R. SMITH MFG. CO.®**  
 MEMBER OF MORRIS GROUP INTERNATIONAL™  
 www.jrsmith.com  
 CUSTOMER DRIVEN SINCE 1926

# INSTALLATION DRAWING

**9930 SERIES TRENCH DRAIN-LOAD CLASS A-C  
 INSTALLED IN ASPHALT**

**WARNING:** Cancer and Reproductive Harm - www.P65Warnings.ca.gov